



Circular Letter No.: 2015.127

Issue Date: 1 June 2015

Application: BEAM Plus NB Version 1.1
BEAM Plus NB Version 1.2

Effective Date: 1 June 2015

SA 8a Wind Amplification

This circular letter announces that, for demonstrating that no pedestrian areas will be subject to excessive wind velocities caused by amplification due to the site layout and/or building design, the following requirements shall be complied with:

- A minimum percentage occurrence of prevailing winds of 75 % annual is required.
- At least 8 of the prevailing wind directions (out of 16) should be tested. If 2 of the 8 directions to be tested are next to each other, it is acceptable to group them together to reduce the number of tests.

Signed : 

Dr. Raymond Yau
Chairperson of Technical Review Committee