



Circular Letter No.: 2017.137

Issue Date: 29 May 2017

Application: BEAM Plus NB Version 1.2

Effective Date: Applicable to projects registered after the issue date

IEQ 8 IAQ in Car Parks

This circular letter announces that Public Transport Interchange (PTI) has to be included in the assessment of the captioned credit.

If there is a PTI in the submitted project, the client shall demonstrate the design of the ventilation system of the PTI meeting the guidelines given in ProPECC PN 1/98.

To achieve IEQ 8, the following submittals shall be provided:

1. In Provision Assessment (PA), specification and measurement methodology (including proposed sampling points) shall be provided to demonstrate the commitment of carrying on-site measurement in Final Assessment (FA), and ensure the measurement results of air quality at enclosed carpark and PTI meet the guidelines given in ProPECC PN 2/96 and ProPECC PN 1/98 respectively.
2. In FA, on-site measurement conducted by suitably qualified person (e.g. Certificate Issuing Body (CIB)) shall be provided to demonstrate the air quality at the enclosed carpark and PTI meets the guidelines given in ProPECC PN 2/96 and ProPECC PN 1/98 respectively.

A handwritten signature in blue ink, appearing to be "A" or a similar stylized name.

Mr KM So
Chairperson of Standards Sub-committee